

Accessibility Site Survey of Selected Items For Title 24 of the California Building Code



California Academy for Liberal Studies Middle School
7350 North Figueroa Street
Los Angeles, CA 90041

Certificate of Occupancy: 7-Change of Use

This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report.

January 26, 2010



Main Entrance

No signage

No accessible hardware on gate



Path of Travel

No level landing at office main entrance



Main Entrance

Bottom 10 inches of main entrance not smooth



Parking at Main Entrance

No truncated domes
Not outlined on left



Signage

No ISA on sign



Signage

No ISA on latch side signage



Signage

No ISA on latch side signage



Restroom

No ISA signage at unisex teachers work room
Coat hook greater than 48 inches



Restroom

38 inches of clearance (42 required)



Elevator

No Braille below chase way jamb signage
No hall call lanterns



Drinking Fountain

No high-low




Dining Tables

Tables not accessible by design



Dining area

Dining area not accessible
Stair access only



Parking

Parking space not outlined on left



Path of Travel

No truncated domes