

# Accessibility Site Survey of Selected Items For Title 24 of the California Building Code



College Ready Academy High School #4  
644 West 17<sup>th</sup> Street  
Los Angeles, CA 90015

Certificate of Occupancy: 6-New School

This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report.

December 14, 2009



### **Main Entrance**

Construction Summer 2009  
Non-compliant Main entrance  
No 12 inch extensions on handrails  
No 60 inch level landing at top  
Tripping Hazards



### **Handrail to Main Entrance**

Window grating covers right handrail



### **Ramps**

Handrails greater than 1 ½ inch from rail




### **Path of Travel**

Ramp with one handrail

Non-compliant gate

No accessible route from the public right of way



### **Route from Public Right of Entrance**

Non-compliant gate

Bottom 10 inches of the gate not smooth

No pedestrian crosswalk