

# Accessibility Site Survey of Selected Items For Title 24 of the California Building Code



Renaissance Arts Academy  
1800 Colorado Boulevard  
Los Angeles, CA 90041

Certificate of Occupancy: 7-Change of Use

This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report.

December 14, 2009



### **Parking Lot**

No accessible route from the public right of way to the main entrance

No accessible parking



### **Ramp to Main Entrance**

No handrails on left

No bottom extensions on handrails



### **Restroom**

Pipes not wrapped



### **Passenger Loading Zone**

Non-compliant loading zone  
No accessible route to school



### **Threshold**

Non-compliant threshold



### **Ramp to Break Room**

Does not have 80 inches of clear space



## **Stairs**

No stripping on stairs